



RCBO Certificat.

As the importer of OMU System RCBOs (miniature circuit breaker + residual current devices)

MIXVILL Kft. declares that these products were produced and are in accordance with the following European norms:

IEC 61008-1:1996

IEC 61008-2-1:1990

The products also have SEMKO certification and test report.

Main technical parameters:

In: 6, 10, 13, 16, 20, 25, 32 A

(30 mA, B, C characteristic)

Un: 230V AC

Breaking capacity: 6 kA

Type: A 2.pol, 1 modul

Debrecen, 2024-03-13

Mixvill Kft